




SmartExhaust™ Testing Guide



With power to the SmartExhaust™ switch -

	1	2	3	4
ACTION	<p>Turn Delay and Ventilation dial to 30 minutes, flip switch to ON</p> 	<p>Wait 15 seconds, flip switch to AUTO</p> 	<p>Turn Delay dial to 0 minutes, wait 15 seconds</p> 	<p>Turn Ventilation dial to 60 minutes, wait 15 seconds</p> 
RESPONSE	<p>Light and fan should come on</p>	<p>Light should go off and fan should continue to run</p>	<p>Fan should go off</p>	<p>Fan should go on</p>

TESTING COMPLETE. RETURN DIALS TO PREFERRED SETTINGS.

If after following this procedure the SmartExhaust™ is not responding properly please contact Technical Support at (781)834-1600 or info@aircycler.com.