



NOTES:

1. Order for wires on terminal block may not be as shown
2. Connect Neutral, Line and Ground (if required) to motor colors as shown
3. For multiple locations, the switch must be wired off the same circuit or the same phase of the load center.
4. Cap off Red/Yellow wire on each switch
5. Do not use 3 way wiring system

**1 PHASE INLINE FAN
w/ 2 FD60EM 60-MIN TIMERS
WIRING DIAGRAM**

Rev. 02

Date: 28-Feb-2020

