



NOTES:

1. Order for wires on terminal block may not be as shown
2. Connect Neutral, Line and Ground (if required) to motor colors as shown
3. Cap off Red/Yellow wire on each switch
4. Do not use 3 way wiring system

1 PHASE INLINE FAN
w/ 1 IPHS5 HUMIDITY SENSOR
STANDARD WIRING DIAGRAM

Sheet: 1 of 1

Rev. 01

Date: 12-Feb-2020

 **fantech**[®]
a systemair company